



Wels, January 8th 2015

COMPLIANCE SETUP GB WITH G 83/2 AND G 59/3

Fronius International GmbH

hereby confirms, that the inverters

- / **Fronius Galvo 1.5-1 to Fronius Galvo 3.1-1**
- / **Fronius IG TL 3.0 to Fronius IG TL 3.6**
- / **Fronius Symo 3.0-3-S to Fronius Symo 4.5-3-S**
- / **Fronius Symo 3.0-3-M to Fronius Symo 10.0-3-M**
- / **Fronius Primo 3.0-1 to Fronius Primo 3.6-1**

are adjusted according to the requirements given in Engineering Recommendation G83/2 provided that the setup is "GB" is selected.

Accordingly, the inverters

- / **Fronius Symo 12.5-3-M to Fronius Symo 20.0-3-M**
- / **Fronius IG TL 4.0 to Fronius IG TL 5.0**
- / **Fronius Agilo 75.0-3 – 100.0-3**
- / **Fronius IG Plus**
- / **Fronius Eco 25.0-3-S to Fronius Eco 27.0-3-S**
- / **Fronius Primo 4.0-1 to Fronius Primo 8.2-1**

are adjusted according to the requirements given in Engineering Recommendation G59/3 provided that the setup is "GB" is selected.

Fronius International GmbH

Solar Energy Division

Froniusplatz 1

A-4600 Wels

A handwritten signature in blue ink, appearing to read "Thomas Mühlberger".

DI Thomas Mühlberger

Head of Solution Management