



SHIFTING THE LIMITS

Wels, June 26<sup>th</sup> 2013

## DOCUMENT OF COMPLIANCE FRONIUS GALVO

### Fronius International GmbH

Document of Compliance 07013

- / **Product:** Automatic AC disconnect switch
- / **Type:** Fronius Galvo Setup DE, FRA, AUT, GRE, POR, EXC
- / **Intended Use:**

The product is to be used as an automatic AC disconnect switch that is inaccessible to the DSO as a safety function between the PV system and the low-voltage grid. The automatic AC disconnect switch is an integral part of the PV inverter type:

/ **Fronius Galvo 1.5-1 – 3.1-1**

- / **Test specification:**

DIN V VDE 0126-1-1: 2006-02 "Automatic switching center between a grid connected generator and the public low-voltage-grid"

The safety concept of the above product tested with the report of 10.06.2013, ref. 5001204-3971-0003/183926 (VDE Testing and Certification Institute) corresponds to the safety requirements for the intended purpose valid at the time this certificate was issued.

### Fronius International GmbH

Solar Electronics Division  
Froniusplatz 1  
A-4600 Wels

Ing. Prok. Martin Hackl  
Head of Solar Electronics Division